

Solicitation Number: 2021-006-RFP Addendum Number: 2

Fire System Testing, Inspection, Monitoring, and Repair

Due Date and Time: August 26, 2020 at 1:59 pm Arizona time

A signed copy of this addendum must be included with proposal

The following questions were submitted in writing prior to the deadline:

Q1 - Is a full dump of the AFFF required?

A1 - No, a full dump is not required. The Airport flows enough foam to get a good sample to test.

Q2 - If we perform a full dump of the AFFF, who is responsible for the refilling of the bladders with the foam mixture after the dump?

A2 - The contractor will be responsible for replacing AFFF.

Q3 - If we are responsible, tech time and pricing for the foam will need to be included in the contract?

A3 - No, the contractor would bill the Airport separate from the contract for refilling the bladders. However, testing the foam and the system would be included under the contract and should be included in Offeror's proposal.

Q4 - If we need to include in quote, how large are the bladders for each AFFF tank? We would need to know how much foam mixture would need to be included to refill after a dump.

A4 - This is not applicable. Please see answer to question three above.

Q5 - Can signatures be scanned/electronic or must they be wet?

A5 - PMGAA will accept scanned/electronic signatures.

[Empty rectangular box for content]

ALL OTHER PROVISIONS OF THE SOLICITATION SHALL REMAIN IN THEIR ENTIRETY.

<p>Offeror hereby acknowledges receipt and understanding of above addendum.</p> <p>_____ Signature Date</p> <p>_____ Print Name and Title</p> <p>_____ Name of Company</p>	<p>The above referenced Solicitation Addendum is hereby executed August 17, 2020 at PMGAA, Mesa, Arizona.</p> <p style="text-align: center;">Marian Whilden</p> <p style="text-align: center;">_____ Procurement Coordinator Phoenix-Mesa Gateway Airport Authority</p>
---	---